

	<b>Jackshaft Positioning</b>	<b>Parallel Positioning</b>	<b>Fully Metered</b>
<b>Appliaction Specifics</b>			
<b>Duel Fuel Firing</b>			
Low-fire changeover only	Option	Option	Option
Full-load simultaneous firing	<b>Not Recommended</b>	<b>Not Recommended</b>	Option
<b>Single/Multiple Burners</b>			
Single Burner	Option	Option	Option
Multiple Burners	<b>Not Recommended</b>	<b>Not Recommended</b>	Option
<b>Furnace Conditions</b>			
Pressurized	Option	Option	Option
Balanced Draft (FD & ID Fans are used)	<b>Not Recommended</b>	<b>Not Recommended</b>	Option
<b>Air Heater Type</b>			
Lungstrom (Rotary)	<b>Not Recommended</b>	<b>Not Recommended</b>	Option
Tubular	Option	Option	Option
<b>Stack Options</b>			
Independent	Option	Option	Option
Common & slight effect on furnaace pressure	Option	Option	Option
Common & significant effect on furnace pressure	<b>Not Recommended</b>	<b>Not Recommended</b>	Option
<b>F.D. Fan Location</b>			
Integral with windbox	Option	Option	Option
Remote	<b>Not Recommended</b>	Option	Option
<b>Air Composition</b>			
Constant	Option	Option	Option
Variable but slight	Option	Option	Option
Variable & significant	<b>Not Recommended</b>	<b>Not Recommended</b>	Option
<b>Fuel Composition</b>			
Clean	Option	Option	Option
Variations	<b>Not Recommended</b>	<b>Not Recommended</b>	Option